

Annexure C

No. 416

Dated: 04/08/25

It is certified that an inspection team headed by Executive Engineer Mr. Sonu (Name of Officers with designation) from PHED DIVISON PURNEA BIHAR inspected the

**SCHOLARS INTERNATIONAL SCHOOL B.KOTHI, PURNEA, Shree khagesh nagar,**

mauza-sukhsena Barhara kothi purnea Bihar 854203. (Name & Add of the school) on 13/06/25 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 358

dated 13/06/25 of Public Health Engineering Department (PHED Lab) certified that

the **SCHOLARS INTERNATIONAL SCHOOL B.KOTHI, PURNEA.** (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/08/26

Signature with Seal: .....  
Name : .....  
Designation : .....  
Name & Address of the Office/ Department: .....

To  
Scholars International School B.kothi  
Purnea, Shree khagesh nagar, mauza-  
sukhsena Barhara kothi purnea Bihar  
854203  
(Name & Address of the Institution)

Note: The certificate is to be issued by  
authorized officer / PHED Lab / local bodies

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Testing Report**  
**Sample Given By :- Rajiv Kumar**

District Name: Purnea

Division Name: P.H.Division,Purnea

Month: Jun 2025

SL. No.	Block	Panchyat	Village/Habitation	Location of source	Type of source	Parameters										Remarks
						pH	Turb.	EC	TDS	TH	Cl	Alka.	Fe	Ca	Mg	
1	B.Kothi	Sukhsena East	Sukhsena East Ward No:-8	Scholars International School	Tap Water	7.2	4.0	712	358	117.6	81.04	156.8	0.9	54.88	9.52	जल नमूना का संग्रह स्वयं लाभार्थी के द्वारा किया गया है। जल शुद्धता की गारंटी जल संग्रह करने के तरीके एवं संयोजकों को उपर निर्भर करता है।
Desirable Limit*						6.5-8.5	5.0	-	500	200	250	200	1.0	75	30	
Permissible Limit* in absence of alternate source						NR	10.0	-	2000	600	1000	600	N.R	200.0	100	

*[Signature]*  
13/06/25  
Chemist

P.H. Division, Purnea

*[Signature]*  
13/06/25

A.E.

P.H. Sub Division, Purnea

*[Signature]*  
13.06.25

Executive Engineer  
P.H. Division, Purnea

**Executive Engineer**  
**P.H. Division, Purnea**